

EXP 43

WARNING

In order to ensure the smooth operation of the reverse osmosis apparatus, special attention must be paid to certain parameters.

The maximum allowable values are indicated below :

IC < 3

Chlorine \approx 0 ppm

pH < 10

Fe < 0.01 ppm

TH < 0.5° f

Filter outlet 1 μ

Active charcoal filter outlet

Filter outlet 1 μ

Filter outlet 1 μ

Softened water outlet

FAILURE TO COMPLY with these indications may lead to the cancellation of the guarantee on the equipment (particularly reverse osmosis modules).