

<p style="text-align: center;">PROGRAMMING SHEET STANDARD UNIT PILOT M 2</p>	<p style="text-align: center;">EXP 74</p>	<p style="text-align: center;">A</p>
--	--	---

Softener type

--	--	--	--

Ref. no. :

To proceed with programming, press P 99 to access the menu.

Entry	Parameter	Information			Correction key	Display
P 0 1	Operating mode	1 - Pure volume regeneration Simplex and Multiplex 2 - Forecast volume regeneration 3 - Regeneration frequency in number of days between regenerations 4 - Regeneration on specified days of the week 5 - Regeneration in number of hours between regenerations 6 - Regeneration in alternating volumes			C	
P 0 2	Hardness of water	Hardness of water in CaCO ₃ mg/l = °TH x 10			C	
P 0 3	Time set	Clock reading at time of programming for modes 1 - 2 - 3 - 4 - 5			C	
P 0 4	Time of regeneration	Time chosen for regeneration, for modes 2 - 3 - 4			C	
P 0 5	Programming day	1 Monday - 2 Tuesday - 3 Wednesday - 4 Thursday - 5 Friday 6 Saturday - 7 Sunday, for modes 3 - 4 chosen in P 0 1			C	
P 0 6	Interval between regenerations in specified days	E.g. Monday 1, Saturday 6 - for mode 4 chosen in P 0 1			C	
P 0 7	Interval between two regeneration in number of days	Interval in no. of days from 2 to 39, for mode 3 chosen in P 0 1			C	
P 0 8	Regeneration frequency in hours	Interval in no. of hours from 0 to 23, for mode 5 chosen in P 0 1			C	
P 0 9	Cycle correction	Depending on nature of raw water from 0 to 29 % (initial setting - 10%)			C	
P 1 2	Type of apparatus to be ordered	Enter 4 for 9000			C	
P 1 3	Volume of resin	Depending on type of apparatus			C	
P 1 4	Meter calibration	No. of litres between meter pulses Enter 1 for no meter			C	
P 1 6	Salt weight	According to E.C. : Standard : 125 g/l/r - Maximum : 180 g/l/r			C	
P 1 7	Cycle	Unit calculates cycle automatically				
P 1 8	Brine	Unit calculates brine automatically				
P 2 0	Regeneration phase times	Backwash	Suction + slow rinse	Quick rinse	C	
P 0 0	Operation	Display cycle or time depending on mode chosen in P 0 1				

Note : If a value needs to be modified after completion of programming : press P 9 9 - Press the key corresponding to the desired modification - Press C for correction - Modify the programme and type P 0 0.