

VALEURS A RESPECTER SUR LES DIFFERENTS RESEAUX

TITRES	EAU DE VILLE	EAU ADOUCT	ECS CUISINE	TOUR AERO	CHAUFFAGE	EAU GLACEE
pH	7 - 8	7 - 8	7 – 8	8 - 9,3	7 - 9	7 - 9
TH °f	22 - 30	0	3 - 10	0 - 10	0 - 5	0 - 5
TA °f	0	0	0	0 - 10	5 - 10	0 - 10
TAC °f	15 - 25	15 - 25	15 - 25	35 - 55	15 - 30	15 - 30
Cl mg/l	15 - 25	15 - 25	15 - 25	30 - 60	15 - 25	15 - 25
NO2 mg/l					-> 800	-> 800
Mo mg/l						
SiO2 ppm	9 - 12	-	19 - 22			
Fer ppm			< 0,2	< 0,2	< 1	< 1
Coloration	claire	claire	claire	claire	ambré	claire
TAC TOUR ----- TAC APPOINT				maxi 3,5		
TOUR S ml/m3				60 - 220		
TANINS mg/l				-		